



Parijat ActiveX/OCX for Honeywell

7a. UDC500 serial master

Properties - HWctI500	
HWctI500 HWG500	
Alphabetic Categorized	
(About)	
(Custom)	
(Name)	HWctI500
BaudRate	6
Busy	False
CommPort	1
DataWords	0
DeviceType	4 - Gateway
Index	
Left	4440
OpCode	0 - Scan_Alarms
Parity	1
PLCAddr	1
PollingInterval	0
StopBits	0
SumOfLenCodes	0
Tag	
TimeOut	2000
Top	120
TransactionTime	0
Tuning	0

7b. DCM(620-48/52) ABC serial master

Properties - HWellABC	
HWellABC HWellABC	
Alphabetic Categorized	
(Name)	HWellABC
BaudRate	8
BitPacking	1
Busy	0
CommPort	1
DataBits	1
DataWords	10
Index	
Left	4560
Parity	0
PLCAddr	1
PLCFunction	0
StopBits	0
Tag	
TimeOut	1000
Top	240

Interface: Honeywell Gateway 500 via serial port.

Methods: Portopen, Refresh, Compareinfo

Events: OutCome (fires when a communication transaction completes)

Throughput: Reads 120 consecutive words in 130 msec.

Interface: Honeywell IPC620 via 620-0048 or 0052 via data Collection Modules.

Methods: Portopen, Refresh, Compareinfo

Events: OutCome (fires when a communication transaction completes)

Throughput: Reads 120 consecutive words in 120 msec.

For More Info:

Overview of Parijat Drivers: [Click here](#)